

**58.05**13/04/2017  
VC136**ON-SITE AMENITY AND FACILITIES****58.05-1**13/04/2017  
VC136**Accessibility objective**

To ensure the design of dwellings meets the needs of people with limited mobility.

**Standard D17**

At least 50 per cent of dwellings should have:

- A clear opening width of at least 850mm at the entrance to the dwelling and main bedroom.
- A clear path with a minimum width of 1.2 metres that connects the dwelling entrance to the main bedroom, an adaptable bathroom and the living area.
- A main bedroom with access to an adaptable bathroom.
- At least one adaptable bathroom that meets all of the requirements of either Design A or Design B specified in Table D4.

**Table D4 Bathroom design**

	<b>Design option A</b>	<b>Design option B</b>
Door opening	A clear 850mm wide door opening.	A clear 820mm wide door opening located opposite the shower.
Door design	Either: <ul style="list-style-type: none"> <li>▪ A slide door, or</li> <li>▪ A door that opens outwards, or</li> <li>▪ A door that opens inwards that is clear of the circulation area and has readily removable hinges.</li> </ul>	Either: <ul style="list-style-type: none"> <li>▪ A slide door, or</li> <li>▪ A door that opens outwards, or</li> <li>▪ A door that opens inwards and has readily removable hinges.</li> </ul>
Circulation area	A clear circulation area that is: <ul style="list-style-type: none"> <li>▪ A minimum area of 1.2 metres by 1.2 metres.</li> <li>▪ Located in front of the shower and the toilet.</li> <li>▪ Clear of the toilet, basin and the door swing.</li> </ul> The circulation area for the toilet and shower can overlap.	A clear circulation area that is: <ul style="list-style-type: none"> <li>▪ A minimum width of 1 metre.</li> <li>▪ The full length of the bathroom and a minimum length of 2.7 metres.</li> <li>▪ Clear of the toilet and basin.</li> </ul> The circulation area can include a shower area.
Path to circulation area	A clear path with a minimum width of 900mm from the door opening to the circulation area.	Not applicable.
Shower	A hobless (step-free) shower.	A hobless (step-free) shower that has a removable shower screen and is located on the furthest wall from the door opening.

	Design option A	Design option B
Toilet	A toilet located in the corner of the room.	A toilet located closest to the door opening and clear of the circulation area.

## 58.05-2

13/04/2017  
VC136

### Building entry and circulation objectives

To provide each dwelling and building with its own sense of identity.

To ensure the internal layout of buildings provide for the safe, functional and efficient movement of residents.

To ensure internal communal areas provide adequate access to daylight and natural ventilation.

### Standard D18

Entries to dwellings and buildings should:

- Be visible and easily identifiable.
- Provide shelter, a sense of personal address and a transitional space around the entry.

The layout and design of buildings should:

- Clearly distinguish entrances to residential and non-residential areas.
- Provide windows to building entrances and lift areas.
- Provide visible, safe and attractive stairs from the entry level to encourage use by residents.
- Provide common areas and corridors that:
  - Include at least one source of natural light and natural ventilation.
  - Avoid obstruction from building services.
  - Maintain clear sight lines.

### Decision guidelines

Before deciding on an application, the responsible authority must consider:

- The design response.
- The useability and amenity of internal communal areas based on daylight access and the natural ventilation it will receive.

## 58.05-3

13/04/2017  
VC136

### Private open space objective

To provide adequate private open space for the reasonable recreation and service needs of residents.

### Standard D19

A dwelling should have private open space consisting of:

- An area of 25 square metres, with a minimum dimension of 3 metres at natural ground floor level and convenient access from a living room, or

- An area of 15 square metres, with a minimum dimension of 3 metres at a podium or other similar base and convenient access from a living room, or
- A balcony with an area and dimensions specified in Table D5 and convenient access from a living room, or
- A roof-top area of 10 square metres with a minimum dimension of 2 metres and convenient access from a living room.

If a cooling or heating unit is located on a balcony, the balcony should provide an additional area of 1.5 square metres.

**Table D5 Balcony size**

Dwelling type	Minimum area	Minimum dimension
Studio or 1 bedroom dwelling	8 square metres	1.8 metres
2 bedroom dwelling	8 square metres	2 metres
3 or more bedroom dwelling	12 square metres	2.4 metres

**Decision guidelines**

Before deciding on an application, the responsible authority must consider:

- The design response.
- The useability and functionality of the private open space, including its size and accessibility.
- The amenity of the private open space based on the orientation of the lot, the wind conditions and the sunlight it will receive.
- The availability of and access to public or communal open space.

**58.05-4**

13/04/2017  
VC136

**Storage objective**

To provide adequate storage facilities for each dwelling.

**Standard D20**

Each dwelling should have convenient access to usable and secure storage space.

The total minimum storage space (including kitchen, bathroom and bedroom storage) should meet the requirements specified in Table D6.

**Table D6 Storage**

Dwelling type	Total minimum storage volume	Minimum storage volume within the dwelling
Studio	8 cubic metres	5 cubic metres
1 bedroom dwelling	10 cubic metres	6 cubic metres
2 bedroom dwelling	14 cubic metres	9 cubic metres
3 or more bedroom dwelling	18 cubic metres	12 cubic metres

### **Decision guidelines**

Before deciding on an application, the responsible authority must consider:

- The design response.
- The useability, functionality and location of storage facilities provided for the dwelling.